



Harker Heights Fire Department

401 Indian Trail Harker Heights Texas 76548

(Phone) 254-699-2688 Fax 254-699-7693 e-mail: sphilen@ci.harker-heights.tx.us

Business Fire Inspection

Business: _____ Address: _____ Phone: _____

Owner/Manager: _____ Phone: _____

No Fire Code Violations noted at this time Annual Re-inspection Other: _____

Fire Lanes must be clearly marked and maintained "FIRE LANE NO PARKING TOW AWAY ZONE"
(White 4 inch letters on a red background no less than 30 feet and no greater than 40 feet apart)

This Inspection record is an official NOTICE OF VIOLATIONS and order to comply by this date: _____

Initial Inspection and 1st Re-inspection Free of Charge. All thereafter a fee of \$50.00 each will be charged

1. Signs:

- Post address which is visible from the street. Five inch letters/ numbers on contrasting background
- Post address on rear exits doors. Five inch letters/ numbers on contrasting background
- Post certificate of occupancy near the main exit.

2. Exits:

- Post a sign on or adjacent to exterior door. "This door to remain unlocked during business hours"
- Post adequate exits signs to clearly indicate path of travel and exits
- Provide and or maintain illuminated exit signs and exit way lighting
- Remove all other locks and latches from doors with required panic hardware

3. Fire Extinguisher:

- Provide ____extinguisher(s) 5 lb ABC rating to be located _____
- Post signs indicating location where fire extinguishers are located
- Mount extinguishers where readily available and visible with top of extinguisher no higher than 5 feet
- Travel distance should not exceed 75 feet
- Service fire extinguishers
- Current inspection tag Annual re-inspection due: _____
- Special type extinguisher required based on Occupancy or special hazards Type: _____

4. Utilities Electrical and Gas

- Discontinue use of extension cords in lieu of permanent wiring
- Replace unapproved wiring with permanent wiring in accordance with national electric code
- Repair or replace damaged or spliced electrical cord to the _____
- Label or identify the main electrical/ gas shut off
- Label circuit breakers to indicate areas served
- Remove and maintain 36" inch clearance around the Electrical panel
- Provide cover plates for outlets/boxes located: _____

5. Fire separations:

- Remove obstructions and alterations to fire doors and maintain closing and latching devices
- Repair all fire walls, draft stops and ceilings

6. Fire protection Installations:

- Fire alarm system in need of service
- Service hood and duct extinguishing system
- Maintain access and operation of standpipes, sprinkler control valves
- Sprinkler system needs current certification

7. Housekeeping:

- Remove storage and obstructions from exits, aisles, corridors, stairways and unprotected areas

8. Storage:

- Remove and maintain storage to 18 inches below the level of sprinklers (36 inches for storage piled over 12 feet high)
- Reduce height at least 1 foot below ceiling in non sprinkler areas
- Secure compressed gas cylinders and identify contents with name of product
- Provide a min. of 5 feet clearance between dumpster and building openings or combustible walls or eaves
- Provide 36 inches clearance between heat producing appliances and combustible materials
- Remove combustible storage from mechanical, electrical, and boiler rooms

9. Flammable liquids:

- Remove flammable liquids not stored in original containers or approved safety containers
- Remove flammable liquids in excess of 10 gallons not being used for maintenance
- Store all flammable liquids in an approved storage cabinet and location

10. Knox Box:

- Knox box must be ordered
- Current Emergency contacts
- Current Keys

11. Additional comments or requirements:

The fire Code adopted by the City of Harker Heights requires your prompt attention and corrections of the above conditions to avoid legal action in the municipal court.

Inspector signature: _____

Owner or Occupant: _____ Owner or Occupant: _____
Print Name Signature